

Lea County Electric Cooperative, Inc.

ADDENDUM NO. 1 RESPONSES TO QUESTIONS

Q. Which wood species and coating are preferred?

A. The preference is Southern Yellow Pine wood and 10# creosote treatment.

Q. Would the cooperative be able to receive the poles via rail?

A. No immediate access to rail is available. The material will be delivered to LCEC's main warehouse at 2517 Power Plant Lane, Lovington, NM 88260; ATTN: Bridget Garcia.

This document constitutes Lea County Electric Cooperative's official responses to all questions received by the stated deadline of Monday, July 6, 2026, in accordance with the 2026-03 "Wood Pole Replacement Projects", Version 1.0 dated June 23, 2026.